



Republic of the Philippines
DEPARTMENT OF EDUCATION

Region X

DIVISION OF MISAMIS ORIENTAL

Cagayan de Oro City



*For Posting to Mis. Or. Website!
3/20/15*

DATE: March 18, 2015

DIVISION MEMORANDUM No. s. 2015

**TO: PS District Supervisors/In-Charged
Elementary School Heads
Secondary School Heads
This Division**

FROM: CHERRY MAE L. LIMBACO, Ph.D., CESO V
Cherry Mae L. Limbaco
Schools Division Superintendent

**SUBJECT: Findings of the Bureau of Fire Protection Among Schools of
both Elementary and Secondary Schools Relative to Fire Safety
And Awareness Program**

-
1. Pursuant to DepEd Order No. 72, s. 2012 re: Continuing Fire Safety And Awareness Program (FSAP) in Schools, this Office reiterates all school heads both elementary and secondary schools to intensify the conduct of fire safety inspection of your respective schools.
 2. Enclosed is the findings of the Bureau of Fire Protection of all schools that have been inspected by the Provincial Fire Marshals (PFMs) for your ready reference.
 3. For more information, please call Mr. Norberto E. Rosales, EPS/DPFC with cell number 09177948730.
 4. For strict compliance.

CLL/ner

						FO1 Rio R Ferrer	fire extinguishers		
6	Kibungsood National High School	Barangay Kibungsood, Magsaysay, Mis. Or.	2014-05-185	5/13/2014	FO2 Julius Christian R FO2 Kenneth S Nacaya FO1 Josnua I Mastlog FO1 Rio R Ferrer	* Dilapidated/obsolete all electrical wirings * No provision of portable fire extinguishers			
7	Lunao Central School	Barangay Lunao, Ginggoog City	2014-08-18	5/12/2014	FO3 Andrew O Gatasi FO2 Kenneth S Nacaya	* No provision of approved type secondary exit			
8	Don Restituto Central School	National Highway, B#	2014-5-187	5/7/2014	SFO1 Antonino E	* No provision of approved			
		Ginggoog City			FO3 Geoffrey V Ramirez FO2 Vincent M Pinaaling FO1 Rio R Ferrer	type secondary exit			

MISAMIS ORIENTAL DIVISION

BALINGASAG FS

No.	NAME OF SCHOOL	ADDRESS	MISSION ORDER	DATE INSPECTED	INSPECTED BY	NOTED VIOLATION	DATE OF FSIC ISSUED	REMARKS
-----	----------------	---------	---------------	----------------	--------------	-----------------	---------------------	---------

1	BALINGASAG CENTRAL SCHOOL	BRGY. 4, BAL. MIS. OR	Inspection Ordre # 2014-05-0017	5/6/2014	INSP. BANAC/SFO4 OBSIOMA/SFO4 DORADO/FO2 GENTALLAN	Insufficient Fire Exits/ No Fire fighting appliance	Issued NTC
2	BALIWAGAN CENTRAL SCHOOL	BRGY. BALIWAGAN, BAL. MIS. OR	Inspection Ordre # 2014-05-0018	5/6/2014	INSP. BANAC/SFO4 OBSIOMA/SFO4 DORADO/FO2 GENTALLAN	Insufficient Fire Exits/ Exit doors are not swing outside/ No Fire fighting appliance	Issued NTC
3	LAGONGLONG CENTRAL SCHOOL	LAGONGLONG, MIS. OR	Inspection Ordre # 2014-05-0019	5/7/2014	INSP. BANAC/SFO4 OBSIOMA/SFO4 DORADO/FO2 GENTALLAN	Insufficient Fire Exits/ Exit doors are not swing outside/ No Fire fighting appliance / No signage	Issued NTC
4	SAN JUAN NAT'L HIGH SCHOOL	BRGY. SAN JUAN, BAL. MIS. OR	Inspection Ordre # 2014-05-0020	5/22/2014	INSP. BANAC/SFO4 OBSIOMA/SFO4 DORADO/FO2 GENTALLAN	Insufficient Fire Exits/ Insufficient FF appliances/ Service drop wiring installed inside the ceiling	Issued NTC

BALINGOAN FS								
No.	NAME OF SCHOOL	ADDRESS	MISSION ORDER	DATE INSPECTED	INSPECTED BY	NOTED VIOLATION	DATE OF FSIC ISSUED	REMARKS
1	A. KINOGITAN CENTRAL SCHOOL CONFERENCE HALL	Kinoguitan , Misamis Oriental	2014-05-0025	7-May-14	1. SFO3 Roa, NL Jr. 2. FO2 Jampang, RC 3. FO1 Papillero, GO 4. FO1 Supremo, NH5. 5. FO2 Gentallan, J. OPFM	1. Remove and replace sub-standard wirings 2. install one (1) unit 10 lbs. fire fighting appliance		

4

2	B. ALS AND KINDERGARTEN BUILDING	Kinoguitan , Misamis Oriental	2014-05-0025	7-May-14	1. SFO3 Roa, NL Jr. 2. FO2 Jampang, RC 3. FO1 Papilero, GO 4. FO1 Supremo, NH5. 5. FO2 Gentallan, J OPFM	1. One (1) unit 10 lbs. fire appliance subject for hydro static testing and refill		
3	C. KINOGITAN CENTRAL SCHOOL MAIN BUILDING	Kinoguitan , Misamis Oriental	2014-05-0025	7-May-14	1. SFO3 Roa, NL Jr. 2. FO2 Jampang, RC 3. FO1 Papilero, GO 4. FO1 Supremo, NH5. 5. FO2 Gentallan, J OPFM	1. Remove and replace sub-standard wirings 2. Install "No Smoking " signs 3. INSTALL ADDITIONAL ONE (1) UNIT 10 lbs. ABC type fire extinguisher at front classrooms		
4	D. BUKIDNON STATE UNIVERSITY EXTERNAL STUDIES BLDG.	Kinoguitan , Misamis Oriental	2014-05-0025	7-May-14	1. SFO3 Roa, NL Jr. 2. FO2 Jampang, RC 3. FO1 Papilero, GO 4. FO1 Supremo, NH5. 5. FO2 Gentallan, J OPFM	1. Post " No Smoking " sign 2. Remove and replace octopus wirings 3. install one (1) additional 10 lbs ABC type fire extinguisher 4. Install one (1) emergency lights		

5	E. Kinoguitan Central School pre-school building	Kinoguitan, Misamis Oriental	2014-05-0025	7-May-14	1. SFO3 Roa, NL Jr. 2. FO2 Jampang, RC 3. FO1 Papillero, GO 4. FO1 Supremo, NH5. 5. FO2 Gentallan, J OPFM	1. Remove sub-standard wirings and replace with standard one 2. Install three (3) 10 pounds fire appliance		
6	F. Kinoguitan Central School H.E.-BUILDING	Kinoguitan, Misamis Oriental	2014-05-0025	7-May-14	1. SFO3 Roa, NL Jr. 2. FO2 Jampang, RC 3. FO1 Papillero, GO 4. FO1 Supremo, NH5. 5. FO2 Gentallan, J OPFM	1. Remove installed electrical wirings on said building and other accessories 2. Note : Building not occupied		

JASAAAN FS

No.	NAME OF SCHOOL	ADDRESS	MISSION ORDER	DATE INSPECTED	INSPECTED BY	NOTED VIOLATION	DATE OF FSIC ISSUED	REMARKS
1	Jasaan Central School (Grade 1 Building)	Jasaan, Misamis Oriental	2014-05-0014	6-May-14		No Warning Sign, Defective Electrical Wirings and Outlets, No Fire Alarm, Extinguisher (1 unit 10 lbs)	n/a	For Compliance
2	Jasaan Central School (Grade 2 Building)	Jasaan, Misamis Oriental	2014-05-0014	6-May-14	1 INCD	No Warning Sign, Defective Electrical Wirings and Outlets, No Fire Alarm, Extinguisher (1 unit 10 lbs)	n/a	For Compliance

6

No.	NAME OF SCHOOL	ADDRESS	MISSION ORDER	DATE INSPECTED	INSPECTED BY	NOTED VIOLATION	DATE OF FSIC ISSUED	REMARKS	
3	Jasaan Central School (Grade 3 Building)	Jasaan, Misamis Oriental	2014-05-0014	6-May-14	CRISTINO T. BANAC 2. SFO4 Randy N Obsiona 3. SFO4 Richard R Dorado 4. FO2 Joel B Gentallan	No Warning Sign, Defective Electrical Wirlings and Outlets, No Fire Alarm, Extinguisher (1 unit 10lbs)	n/a	For Compliance	
4	Jasaan Central School (Grade 4 Building)	Jasaan, Misamis Oriental	2014-05-0014	6-May-14		No Warning Sign, Defective Electrical Wirlings and Outlets, No Fire Alarm, Extinguisher (2 units 10 lbs)	n/a	For Compliance	
5	Jasaan Central School (Grade 5 & 6 Building)	Jasaan, Misamis Oriental	2014-05-0014	6-May-14		n/a	n/a	For Compliance	
6	Jasaan Central School (Principal's Office, Science Lab Crime, Library, Computer Rooms, H.E. Room & Supervisor's Office)	Jasaan, Misamis Oriental	2014-05-0014	6-May-14		No Warning Sign, Defective Electrical Wirlings and Outlets, No Fire Alarm, Extinguisher (2 units 10 lbs)	n/a	For Compliance	

MEDINA FS

No.	NAME OF SCHOOL	ADDRESS	MISSION ORDER	DATE INSPECTED	INSPECTED BY	NOTED VIOLATION	DATE OF FSIC ISSUED	REMARKS
1	Dep-Ed Medina District Office	Maanas, Med	04-2014-39	24 April'14	SFO3 Pajaron JM Jr.	1. Dilapidated/defective electrical wirings installation.		1. Advised to replace/replace
					SFO2 Tañola EC			the mentioned defect
					FO1 Balabag VY			fire safety.
						2. (2) units 10 lbs. Fire Extinguisher down gauge/unserviceable.		2. Advised to refill the gauge F.E.
2	Maanas Elementary School	Maanas, Med	04-2014-40	24 April'14	SFO3 Pajaron JM Jr.	1. Unfix electrical wiring, convenience outlets, fuse box and junction box at the H.E. building.		1. Advised to correct the mentioned defects for safety.
					SFO2 Tañola EC			mentioned defects for
					FO1 Balabag VY			safety.

7

									2. Insufficient number of fire extinguisher installed.			2. Advised to install additional (1) unit 10 lbs.
3	San Vicente Elem. School.	San Vicente,	04-2014-41	24 April'14				None			24 April'14	
4	Portulín Natl. High School	Portulín,	Med 04-2014-42	24 April'14	SFO3 Pajaron JM Jr. SFO2 Tañola EC FO1 Balabag VV			1. Unfix/open wire for the convenience outlet at the computer room of DEP-ED building. 2. Unfix/unconcealed wires tapped at the junction box of the Pre-Fab school building. 3. Opened junction box and convenience outlet at the wall of Dep-Ed building. 4. Insufficient number of fire extinguisher installed.				1. Advised to correct the mentioned defect for safety. 2. Advised to correct the mentioned defects for fire safety. 3. Advised to correct the mentioned defects for fire safety. 4. Advised to install additional (1) unit 10 lbs fire safety.
5	Gov. Pelaez Elem. School	Cabug,	Med 04-2014-43	25 April'14	SFO3 Pajaron JM Jr. SFO2 Tañola EC FO3 Gultia GAR			1. Unfix convenience outlet at the Pre-Fab Building # 1. 2. No fire wall at the Pre-Fab Bldg # 1, and NALGO building. 3. Defective thumblers switch, improper connection of drop wire, defective ceiling fan at the Pre-Fab Building # 1. 4. Unfix receptacle at the C.R. of Bagong Lipunan Bldg. # 1.				1. Advised to correct the mentioned defects for fire safety. 2. Construct fire wall at mentioned school building for fire safety. 3. Advised to correct the mentioned defects for fire safety. 4. Advised to correct the mentioned defects for

8

								fire safety.
						5. Unfix convenience outlet of Dep-Ed building # 2		5. Advised to correct the mentioned defects for fire safety.
						6. Unfix ceiling fan switch of Bagong Lipunan Building # 3 & 4.		6. Advised to correct the mentioned defects for fire safety.
						7. Unfix convenience outlet at the Bagong Lipunan Bldg. # 4.		7. Advised to correct the mentioned defects for fire safety.
						8. Insufficient number of F. E. installed.		8. Advised to installed (2) units 10 lbs of Fire Ex-tinguisher.
6	Pahindong Elem. School	Pahindong, M04-2014-44	29 April'14	SFO3 Pajaron JM Jr.	None		29 April'14	
				SFO2 Tañola EC				
				FO3 Gultia GAR				
7	Portulin Elem. School	Portulin, Med 04-2014-46	29 April'14	SFO3 Pajaron JM Jr.	1. Uncovered/defective knife switch at computer room.			1. Advised to correct the mentioned defects for fire safety.
				SFO2 Tañola EC				
				FO3 Gultia GAR				
					2. Unfix thumbler switch at the wall of SEMP building			2. Advised to correct the mentioned defects for fire safety.
8	Medina Nat'l. Comprehensive High School (MNCHS)	North Po., M05-2014-47	05 May '14	SFO3 Pajaron JM Jr.	1. Using undersize wire for the convenience outlet at the computer Laboratory Room.			1. Advised to correct the mentioned defects for fire safety.
				SFO2 Tañola EC				
				FO1 Balabag VV				

								2. Uncovered and jumpered fuse at the safety switch/box at the H.E. Room.				2. Advised to correct the mentioned defects to fire safety.
								3. Unfix fluorescent lamp housing at the Library Room.				3. Advised to correct the mentioned defects to fire safety.
								4. (4) units of F. E. down gauge/ unserviceable.				4. Advised to refill down gauge Fire Extinguishers
								5. (5) units of F. E. stored at the supply office.				5. Fire Extinguishers must be distributed and installed in areas to be protected.
9	Duka Elementary School	Duka, Medina	06-2014-48	06 May '14	SFO3 Pajaron JM Jr.			1. No fire extinguisher installed				1. Advised to install (1) unit 10 lbs fire extinguisher
					SFO2 Tañola EC							
					FO1 Balabag VV							
10	Don Gregorio Pelaez Nat'l. High School	Maanas, Medina	06-2014-49	06 May '14	SFO3 Pajaron JM Jr.			1. (2) units 10 lbs F. E. down Gauge/ unserviceable.				1. Advised to refill the gauge Fire Extinguishers
					SFO2 Tañola EC							
					FO1 Balabag VV							
11	Bulwa Elementary School	Bulwa, Medina	06-2014-49	06 May '14	SFO3 Pajaron JM Jr.			1. Unfix convenience outlet and thumblers at the classrooms of the old school building.				1. Advised to correct the mentioned defects to fire safety.
					SFO2 Tañola EC							
					FO1 Balabag VV							
								2. Using jumpered fuse at the fuse box of the old school building.				2. Advised to correct the mentioned defects to fire safety.

10

12	Medina Central School	North Pob., Medina, Mis. Or.	06-2014-50	07 May '14	SFO3 Pajaron JM Jr.	1. Using jumpered fuse at the fuse box of the principal's office	1. Advised to correct the
					SFO2 Tañola EC	box of the principal's office	mentioned defects for
					FO1 Balabag VY	DADOLE building.	fire safety.
						2. Open-end wire connection for the fluorescent lamp at the Multi- purpose building.	2. Advised to correct the mentioned defects for fire safety.
						3. Defective safety box and ceiling fana at the Bagong Lipunan Bldg.	3. Advised to replace/dis connect the mentioned defective electrical appliance for fire safety
						4. Defective wall fan at the class room of Limketkai building.	4. Advised to disconnect/ remove the mentioned defective wall fan for fire safety.
10							

2ND CONGRESSIONAL DISTRICT

ALUBUIJID FS

No.	NAME OF SCHOOL	ADDRESS	MISSION ORDER	DATE INSPECTED	INSPECTED BY	NOTED VIOLATION	DATE OF FSIC ISSUED	REMARKS
1	LOURDES ELEMENTARY SCHOOL	LOURDES, ALUBUIJID, MISAMIS ORIENTAL	2014-03-30	3/14/2014	FO1 Jalzur Jay J Lignes & FO1 Reynan U Pacuribot	1) No emergency light 2) No exit 3) Unfixed wiring connections 4) No exit & No Smoking signs	Negative	Issued AIR
2	ALUBUIJID CENTRAL SCHOOL	POBLACION, ALUBUIJID, MISAMIS ORIENTAL	2014-04-82	4/24/2014	FO1 Jalzur Jay J Lignes & FO1 Reynan U Pacuribot	1) No emergency light 2) No fire fighting 3) Unfixed electrical wiring 4) No exit & No Smoking signs	Negative	Issued AIR

3	LAGUINDINGAN CENTRAL SCH	Z3, POBLACION, LAGUINDINGAN, MISAMIS ORIENTAL	2014-04-84	4/24/2014	FOI Jalzur Jay J Lignes & FOI Reynan U Pacuribot	1) No emergency light fire fighting appliance 2) insufficient fire fighting appliance 3) No fire alarm system	Negative	Issued AIR
4	LAGUINDINGAN NATIONAL HIGH SCHOOL	Z3, POBLACION, LAGUINDINGAN, MISAMIS ORIENTAL	2014-05-119	5/30/2014	FOI Jalzur Jay J Lignes & FOI Reynan U Pacuribot	1) No emergency light appliance connections building 6 2) No fire fighting 3) Unfixed electrical wiring 4) No exit signs @ new building & 5) No fire alarm system	Negative	Issued AIR

OPOL FS

No.	NAME OF SCHOOL	ADDRESS	MISSION ORDER	DATE INSPECTED	INSPECTED BY	NOTED VIOLATION	DATE OF FSIC ISSUED	REMARKS
1	Opol National Secondary Technical School (new bldg.)	Opol, Misamis Occ, Opol, Misamis Occ, Opol, Misamis Occ	2014-01-003	Jan. 16, 2014	Engr. Arnold G Jaudian, FOI Peter	1. Absence of building permit. 2. Absence of fire fighting appliance @ construction area.		AIR ISSUED
2	Opol National Secondary Technical School (multi-purpose workshop bldg.)	Opol, Misamis Occ, Opol, Misamis Occ	2014-005-06	5/7/2014	G Jaudian, FOI Peter Jack A Sison, FOI Engr. Arnold G Jaudian, FOI Peter Jack A Sison, FOI	1. Absence of automatic emergency light. 2. Absence of manual fire alarm. 3. Absence of fire fighting appliance (fire extinguisher), 1. Absence/No safety switch of several school buildings. 2. No organized Fire Brigade. 3. Absence of fire extinguishers. 4. Flying electrical connections. 5. No secondary exit for four (4) rooms accommodating fifty (50) pupils.		AIR ISSUED
3	Opol Central School	Poblacion, Opol, Misamis Occ, Opol, Misamis Occ	Refer to OPFN	22-Apr-14	Engr. Arnold G Jaudian, FOI Peter Jack A Sison, FOI Venerando			AIR ISSUED

12

MISAMIS ORIENTAL DIVISION

NAAWAN FS

No.	NAME OF SCHOOL	ADDRESS	MISSION ORDER	DATE INSPECTED	INSPECTED BY	NOTED VIOLATION	DATE OF FSIC ISSUED	REMARKS
1	Mat-i National High School	Mat-i, Naawan, Misamis Oriental	2014-02-27	24-Feb-14	FINSP FEDERICO H TOLEDO JR FO2 Irene R Magpulong FO2 Arvie C Fernandez	Absence of "Fire Exit" markings Absence of "No Smoking" markings Absence of Fire Fighting Appliance Failure to conduct Fire Evacuation Drill Failure to organized Fire Volunteer Brigade Failure to submit Insurance Policy		ISSUED NTC
2	Naawan National High School (Emano Building 1)	Naawan, Misamis Oriental	2014-03-27	26-Mar-14	FO2 Irene R Magpulong FO2 Arvie C Fernandez	Failure to install "Fire Exit" sign Submit Insurance Policy, if any. Provide 1 unit Portable Fire Extinguisher		ISSUED NTC
	Naawan National High School (Emano Building 2)	Naawan, Misamis Oriental	2014-03-27	26-Mar-14	FO2 Irene R Magpulong FO2 Arvie C Fernandez	Failure to install "Fire Exit" sign Submit Insurance Policy, if any. Provide 1 unit Portable Fire Extinguisher		ISSUED NTC

13

	Naawan National High School (Tech. & Livelihood Edu. Bldg.)	yan, Naawand-2014-03-14	26-Mar-14	FO2 Irene R Magpulong FO2 Arvie C Fernandez	Failure to install "Fire Exit" sign Insurance Policy, if any. Provide 2 units Portable Fire Extinguisher Install "No Smoking" sign (Computer room, Elect. Room.) Organized Volunteer Fire Brigade	ISSUED NTC
	Naawan National High School (Gov. Oscar Moreno Bldg. 1)	yan, Naawand-2014-03-14	26-Mar-14	FO2 Irene R Magpulong FO2 Arvie C Fernandez	Failure to install "Fire Exit" sign Insurance Policy, if any. Provide 1 unit Portable Fire Extinguisher Install "No Smoking" sign	ISSUED NTC
	Naawan National High School (Gov. Oscar Moreno Bldg. 2)	yan, Naawand-2014-03-14	26-Mar-14	FO2 Irene R Magpulong FO2 Arvie C Fernandez	Install Horizontal "Fire Exit" sign Insurance Policy, if any. Provide 1 unit Portable Fire Extinguisher Install "No Smoking" sign	ISSUED NTC
	Naawan National High School (Gov. Oscar Moreno Bldg. 3)	yan, Naawand-2014-03-14	26-Mar-14	FO2 Irene R Magpulong FO2 Arvie C Fernandez	Install Horizontal "Fire Exit" sign Insurance Policy, if any. Provide 1 unit Portable Fire Extinguisher Improper Electrical Installation	ISSUED NTC
3	Naawan Central School (Ramos Steel Tech. Bldg.)	Naawan, Mid-2014-04-23	23-Apr-14	FO2 Irene R Magpulong FO2 Arvie C Fernandez	Properly arrange electrical wirings/intallation Submit Insurance Policy, if any.	ISSUED NTC

4

Naawan Central School (H.E Bldg.)	Naawan, MID-2014-04-1		23-Apr-14	FO2 Irene R Magpulong FO2 Arvie C Fernandez	Provide 1 unit Emergency ABC type Dry Chemical Portable Extinguisher Insurance Policy, if any. Submit	ISSUED NTC
Naawan Central School (DEP-ED Bldg. 1-4)	Naawan, MID-2014-04-1		23-Apr-14	FO2 Irene R Magpulong FO2 Arvie C Fernandez	Provide 1 unit Emergency ABC type Dry Chemical Portable Extinguisher Insurance Policy, if any. Subject for Final Inspection	ISSUED NTC
Naawan Central School (Bagong Lipunan 1 Bldg. 1 & 2)	Naawan, MID-2014-04-1		23-Apr-14	FO2 Irene R Magpulong FO2 Arvie C Fernandez	Conduct Fire Safety Lecture Seminar Submit Insurance Policy, if any.	ISSUED NTC
Naawan Central School (ABS-CBN Bldg.)	Naawan, MID-2014-04-1		23-Apr-14	FO2 Irene R Magpulong FO2 Arvie C Fernandez	Conduct Fire Safety Lecture Seminar	ISSUED NTC
Naawan Central School (Gabaldon Bldg. 2)	Naawan, MID-2014-04-1		23-Apr-14	FO2 Irene R Magpulong FO2 Arvie C Fernandez	Provide 2 units ABC type Dry Chem. Portable Fire Extinguishers Submit Insurance Policy, if any Request for Fire Drill & Fire Safety Lecture Subject for Final Inspection	ISSUED NTC

15

	Naawan Central School (Gabaldon Bldg. 1)	Naawan, MD-2014-04-		23-Apr-14	FO2 Irene R Magpulong FO2 Arvie C Fernandez	Provide 2 units ABC type Dry Chem. Portable Fire Extinguishers Submit Insurance Policy, if any Request for Fire Drill & Fire Safety Lecture Subject for Final Inspection		ISSUED NTC
4	Tagbalogo Elementary School	Tagbalogo, Naawan, MD-2014-05-		7-May-14	FO2 Irene R Magpulong FO2 Arvie C Fernandez	Improper Electrical Installation Switch Smoking sign No Exit sign		ISSUED NTC
5	Maputi Elementary School (USAID Bldg)	Maputi, Naawan, MD-2014-05-		8-May-14	FINS P FEDERICO H TOLEDO JR FO1 Herman R Fabre	Absence of "Exit" markings Smoking" sign Absence of "No Fighting Appliance Failure to submit Insurance Polic, If any		ISSUED NTC
	Maputi Elementary School (NE Bldg./Grade 4A & 6)	Maputi, Naawan, MD-2014-05-		8-May-14	FINS P FEDERICO H TOLEDO JR FO1 Herman R Fabre	Absence of "Exit" markings Smoking" sign Absence of "No Fighting Appliance Failure to submit Insurance Polic, If any		ISSUED NTC
	Maputi Elementary School (Bagong Lipunan Bldg./Grade 4B & 3B)	Maputi, Naawan, MD-2014-05-		8-May-14	FINS P FEDERICO H TOLEDO JR FO1 Herman R Fabre	Absence of "Exit" markings Smoking" sign Absence of "No Fighting Appliance Failure to submit Insurance Polic, If any		ISSUED NTC

16

	Maputi Elementary School (Bagong Lipunan Bldg./Grade 5B & 5A)				8-May-14	FINSP FEDERICO H TOLEDO JR FO1 Herman R Fabre	Absence of " Exit" markings Smoking" sign Failure to submit Insurance Polic, if any Failure to fixed Electrical System @ 3rd room of Bagong Lipunan Bldg.		ISSUED NTC
	Maputi Elementary School (ICT - Computer Tech. Bldg.)				8-May-14	FINSP FEDERICO H TOLEDO JR FO1 Herman R Fabre	Absence of " Exit" markings Smoking" sign Failure to submit Insurance Polic, if any		ISSUED NTC
	Maputi Elementary School (Kinder Garten Bldg.)				8-May-14	FINSP FEDERICO H TOLEDO JR FO1 Herman R Fabre	Absence of " Exit" markings Smoking" sign Failure to submit Insurance Polic, if any		ISSUED NTC
	Maputi Elementary School (Canteen)				8-May-14	FINSP FEDERICO H TOLEDO JR FO1 Herman R Fabre	Absence of " Exit" markings Smoking" sign Absence of "No Smoking" sign		ISSUED NTC
	Naawan National High School				29-May-14	FO2 Irene R Magpulong FO2 Arvie C Fernandez	Absence of First Aid Fire Fighting Appliance Submit Insurance Policy, If any		ISSUED NTC

INITAOF S

No.	NAME OF SCHOOL	ADDRESS	MISSION ORDER	DATE INSPECTED	INSPECTED BY	NOTED VIOLATION	DATE OF FSIC ISSUED	REMARKS
-----	----------------	---------	---------------	----------------	--------------	-----------------	---------------------	---------

17

1									
2									
3									
4									

CLAVERIA FS

No.	NAME OF SCHOOL	ADDRESS	MISSION ORDER	DATE INSPECTED	INSPECTED BY	NOTED VIOLATION	DATE OF FSIC ISSUED	REMARKS
1	Claveria Central School		2014-05-0015	29-Apr-14				
	a. Bagong Lipunan 2 BLDG					Improper electrical installation system		Install electrical system in accordance with Philippine Electric Code
						Improper installation of doors		Door must be swing in direction of egress
						No First Aid Fire Fighting Appliance		Provide 2 units 10lbs ABC type Fire Extinguisher
								Submit photocopy of Insurance Policy
	b. Bagong Lipunan BLDG and PTA BLDG					No Installed Audible and Visible Alarm System		Required to Install Audible and Visible Alarm System
						No First Aid Fire Fighting Appliance		Provide 2 units 10lbs ABC type Fire Extinguisher
								Submit photocopy of Insurance Policy

	c. DESC BLDG (Principal Office and Science Room)			
	d. Industrial Arts BLDG			
	e. Typhoon Built BLDG A			

FO1 MARK N KIONISALA FO2 SERGIO G CENA JR

19

Defective First Aide Appliances		Refill 3 units 10 lbs ABC type Fire Extinguisher
Safety Breaker not Labeled		Label Properly Safety Breaker
		Submit photocopy of Insurance Policy
No Installed Audible and Visible Alarm System		Required to Install Audible and Visible Alarm System
Improper electrical installation system		Install electrical system in accordance with Philippine Electrical Code
No First Aid Fire Fighting Appliance		Provide 1 unit 10 lbs ABC Type Fire Extinguisher
		Submit photocopy of Insurance Policy
No Installed Audible and Visible Alarm System		Required to Install Audible and Visible Alarm System
Improper electrical installation system		Install electrical system in accordance with Philippine Electrical Code

	f. Typhoon Built BLDG B			
	g. PAGCOR BLDG			
	h. Library HUB			

No First Aid Fire Fighting Appliance		Provide 1 unit 10 ABC Type Fire Extinguisher
No Installed Audible and Visible Alarm System		Required to Install Audible and Visible Alarm System
Improper electrical installation system		Install electrical system in accordance with Philippine Electrical Code
No First Aid Fire Fighting Appliance		Provide 1 unit 10 ABC Type Fire Extinguisher
No Installed Audible and Visible Alarm System		Required to Install Audible and Visible Alarm System
Improper electrical installation system		Install electrical system in accordance with Philippine Electrical Code
No First Aid Fire Fighting Appliance		Provide 1 unit 10 ABC Type Fire Extinguisher
No Installed Audible and Visible Alarm System		Required to Install Audible and Visible Alarm System

20

No.	NAME OF SCHOOL	ADDRESS	MISSION ORDER	DATE INSPECTED	INSPECTED BY	NOTED VIOLATION	DATE OF FSIC ISSUED	REMARKS
						Improper electrical installation system		Install electrical system in accordance with Philippine Electrical Code
						No First Aid Fire Fighting Appliance		Provide 1 unit 10 lbs ABC Type Fire Extinguisher

MANTICAO FS

No.	NAME OF SCHOOL	ADDRESS	MISSION ORDER	DATE INSPECTED	INSPECTED BY	NOTED VIOLATION	DATE OF FSIC ISSUED	REMARKS
1	MANTICAO CENTRAL SCHOOL	P-3, POB, MANTICAO, MIS. OR.	10-2014-07	29-Apr-14	SFO2 DACER SFO1 EYANA EJ	<ol style="list-style-type: none"> 1. No smoke detector installed at the school supervisor's office 2. No automatic emergency lights installed in buildings utilized as classrooms by Bukidnon State University 3. Electrical wiring installation in some classrooms does not conform to the standards of Philippine Electrical Code 4. No "NO SMOKING SIGN" installed 5. No fire fighting appliance installed in some buildings 		
2								
3								
4								
5								
6								

21

	MANTICAO NATIONAL HIGH SCHOOL	PAGAWAN, MANTICAO, MIS. OR.	R10-2014-096	28-May-14	SFO1 CALATRAVA HN	1. No fire alarm systems(manually-operated) installed in all buildings except the Dep.Ed. Building utilized as Principal's Office, Computer Laboratory and School Library 2. No portable fire fighting appliance installed in all buildings 3. Electrical wiring installation at the Computer Laboratory does not conform to the standards of Philippine Electrical Code		ISSUED NOTICE
	CABALANTIAN ELEMENTARY SCHOOL	CABALANTI AN, MANTICAO, MIS. OR.	10-2014-05	30-May-14	SFO1 CALATRAVA HN	1. No fire alarm systems(manually-operated) installed in all buildings 2. Two units 10 lbs portable fire extinguishers subject for refill 3. Electrical wiring installation in most of the existing building does not conform to the standards of Philippine Electrical Code		ISSUED NOTICE
	CABALANTIAN NATIONAL HIGH SCHOOL	CABALANTI AN, MANTICAO, MIS. OR.	10-2014-05	30-May-14	SFO1 CALATRAVA HN	1. Two units 10 lbs portable fire extinguishers subject for refill		ISSUED NOTICE

RR

					FO3 KILOG IE	subject for refill			•SUBJECT FOR REIN

LUGAIT FS

No.	NAME OF SCHOOL	ADDRESS	MISSION ORDER	DATE INSPECTED	INSPECTED BY	NOTED VIOLATION	DATE OF FSIC ISSUED	REMARKS
1	Biga Elem. School	Biga Lugait, M	R10-2014-04-206	29-Apr-14	FO1 Escabal/FO1 Sarsuelo	1. insufficient number of first aide firefighting appliance. 2. Unfix electrical wiring installation.		issued NTC/submitted undertakings
2	Calangahan, Elem. School	Brgy. Calangahan, Lugait, Mis. Or.	R10-2014-04-207	29-Apr-14	FO1 Escabal/FO1 Sarsuelo	1. No firefighting appliance installed. 2. Improper electrical wiring installation. 3. No fire insurance policy presented during the conduct of inspection.		issued NTC/submitted undertakings
3	Lugait Central School	p. Lugait, Mis.	R10-2014-04-209/Task Force I.O number	30-Apr-14	FO3 Arellano/FO1 Gaid (Task Force Member)	1. Presence or utilization of substandard electric fan were found in some of the classrooms of Lugait, Central School. 2. Obstructed fire exit at District Office. 3. Improper/substandard electrical wiring installation in some of the Classrooms of Lugait Central School.		issued NTC/submitted undertakings

29

4	Lugait Central School (Task Force inspection to all DepEd district offices)	Brgy. Lower Talacogon, Lugait, Mis. Or.	R10-2014-05-210	30-Apr-14	SINSP REYNANTES LORONO/INS P FRANKLIN D PABLONA/IN SP FEDERICO H TOLEDO JR/SFO4 Arnulfo G Nabua II /FO1 Venerando S Reyes III	1. Presence or utilization of substandard electric fan were found in some of the classrooms of Lugait, Central School. 2. Obstructed fire exit at District Office. 3. Improper/substandard electrical wiring installation in some of the Classrooms of Lugait Central School.		issued NTC
5	Talacogon Elem. School	Brgy. Lower Talacogon, Lugait, Mis. Or.	R10-2014-05-210	5-May-14	FO1 Escabal/FO1 Gaid	All previous requirements noted in the NTC issued have been sufficiently complied.	5-May-14	Issued FSIC
6	Kaluknayan Elem. School	Brgy. Kaluknayan, Lugait, Mis. Or.	R10-2014-05-211	5-May-14	FO1 Gaid/FO1 Sarsuelo	1. No first aide fire protection appliance installed. 2. Using jumpered fuses 3. No separate safety switch/circuit breakers in every room. 4. No fire insurance policy presented during the conduct of inspection		issued NTC/submitted undertakings
7	Aya-aya elem. School	Brgy. Aya-aya, Lugait, Mis. Or.	R10-2014-05-212	6-May-14	SFO4 Nabua/FO1 Bones	1. Insufficient number of fires aide firefighting appliance. 2. No fire alarm system (electrically operated). 3. Submit schedule for second fire drill.		issued NTC/submitted undertakings
8	Betahon, Elem. School	Brgy. Betahon, Lugait, Mis. Or.	R10-2014-05-213	6-May-14	FO1 Escabal/FO1 Gaid	1. Insufficient number of firefighting appliance. 2. No fire insurance policy presented during the conduct of inspection.		issued NTC/submitted undertakings
9	Lugait National high School	Brgy. Lower Talacogon, Lugait, Mis. Or.	R10-2014-05-214	7-May-14	FO1 Gaid/FO1 Sarsuelo	1. Improper electrical wiring installations, using substandard electric fans, and substandard sizes of wire have been observed in some classrooms. 2. Defective Fire Alarm bell. 3. No fire insurance policy presented during the conduct of inspection.		issued NTC/submitted undertakings

24

Prepared by:



Venerando S. Reyes III
FOI BFP

FSES/ IID, NCO

Noted by:



FRANKLIN O. RATUNIL
CINSP BFP

Provincial Fire Marshal, Mis-O





Republic of the Philippines
 Department of the Interior and Local Government
BUREAU OF FIRE PROTECTION
OFFICE OF THE PROVINCIAL FIRE MARSHAL
 2nd Flr. COFD Bldg, Captain V Roa St., Cagayan de Oro City
 Tel no. (08822)745-883



EL SALVADOR DIVISION

4	El Salvador Central School	Poblacion, El Salvador City	014-004-05	22-Apr-14	Engr. Arnold G Jaudian, FO1 Peter Jack A Sison, FO2 Joel B Gentallan	1. Absence of latest electrical inspection certificate.		AIR ISSUED
						2. Insufficient emergency lighting system.		
						3. No organized Fire Brigade lecture & seminar.		
						4. Insufficient fire fighting appliance/fire extinguisher.		
						5. Absence of Manual Fire Alarm Bell.		
						6. Fire Insurance Policy Contract not presented.		
						7. No proper disposal of garbage.		
						8. Subject for re-inspection.		

GINGOOG DIVISION (GINGOOG FS)

No.	NAME OF SCHOOL	ADDRESS	MISSION ORDER	DATE INSPECTED	INSPECTED BY	NOTED VIOLATION	DATE OF FSIC ISSUED	REMARKS
1	BRGY 18-A ELEMENTARY SCHOOL	BRGY. 18-A, GINGOOG CITY	2014-05-204	JUNE 4, 2014	FO2 ADEVA FO1 FERRER	1) PROVIDE/INSTALL FIRE EXTINGUISHER AT EACH FLOOR 10lbs DRY TYPE 2) INSTALL SMOKE/HEAT DETECTOR AT OFFICE & LIBRARY SECONDARY EXIT AT GRADE 2 BUILDING INSTALL DRY STANDPIPE SYSTEM	NO ISSUANCE	
1	Gingoog Manpower Training School	P#3, Babybay Lunao, GC	2014-3-101	3/20/2014	SFO# Emmanuel F Delima	* No provision of Emergency lights		
					FO2 Juluis Christian R Adeva			
					FO2 Kenneth S Nacaya	* No provision of Fire Extinguishers		

1 of 25